

∂ Fortress Interlocks

Protecting People, Protecting Industry.

"For anyone who needs to protect people and machinery, Deebar is the interlock company that offers reliable, cost effective customised solutions"

MAINTENANCE PROCEDURE

To maintain a smooth operation of the Deebar Fortress interlocking systems, the locks should be checked regularly for their correct operation.

IMPORTANT:

Under no circumstances should dry lubricant be used

Generally little maintenance is required on Deebar Fortress Interlocks if used in a dry and dust free area. Locks generally just need blowing out followed by spraying in a wet lubricant such as WD40 or any wet lubricant. **NO** dry lubricant is to be used as this will clog the mechanism and render the locks in-operable.

If, at any time, the Deebar Interlocks become difficult to operate, due to dirt and grime which could be imbedded or built up in the locking mechanism, apply the following procedure:

- 1. Firstly, remove the lock
- 2. Spray paraffin, Grade "A" if possible, into the locking mechanism.
- 3. Once the dirt and grime becomes a liquid form, hold the lock upside down to remove the liquid dirt.
- 4. Allow the lock to dry.
- When completely dry, give the lock mechanism a couple of sprays of wet lubricant to ensure the smooth operation once again.

IMPORTANT

- In the event of malfunctioning locks, immediate steps should be taken to repair or replace any defective items
- Panel door interlocks should be checked to ensure that operating keys can only be removed with the doors locked.
- In the case of key exchange boxes, these should be checked to ensure that access keys can only be released when isolation keys are trapped.
- All electrical switches should be checked for correct operation and function.

FOR FURTHER INFORMATION, PLEASE CONTACT US:

JOHANNESBURG

15 Main Reef Road Primrose Ext.1 Germiston 1401

Tel: (011) 873-4332/3/4/5 Fax:(011) 825 6984

E-Mail: sales@deebar.co.za Web Page: www.deebar.co.za

RUSTENBURG

11 ACBO Industrial Park Rustenburg 0299 Tel: (014) 596-5141/6734 Fax: (014) 596-5898 E-Mail: rust@deebar.co.za

NORTHWEST

25 Neethling Street, Stilfontein Tel: (018) 484 - 1864/5 Fax: (018) 484 - 1869

Email: klerksdorp@deebar.co.za



